



Maple Elementary | Site Analysis

3501 Kimber Dr I Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017 NAC Architecture 837 North Spring Street, 3rd Floor Los Angeles, CA 90012 Contact: 323.475.8075 E-mail: lochoa@nacarchitecture.com Website: www.nacarchitecture.com





ILDING		PLANTED AREA
DING		SAND
		IMAGE KEYS
	(#)	BUILDING NUMBERS

- 2. CHILD CARE
- **3. PORTABLE KINDERGARTEN**
- 4. PERMANENT CLASSROOM
- 5. PERMANENT CLASSROOM

7.	PERMANENT CLASSROOM
8.	PERMANENT CLASSROOM

- 9. PORTABLE CLASSROOM
- X. LUNCH SHELTER



Maple Elementary | *Site Analysis*

3501 Kimber Drie , Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017

Neighborhood Presence

mage (



LEGEND



BUILDINGS

1. MULTI-PURPOSE/ ADMINISTRATION/ 6. PERMANENT CLASSROOM FOOD SERVICE

- 2. CHILD CARE
- **3. PORTABLE KINDERGARTEN**
- 4. PERMANENT CLASSROOM

5. PERMANENT CLASSROOM



8. PERMANENT CLASSROOM

9. PORTABLE CLASSROOM

X. LUNCH SHELTER



Maple Elementary's primary pedestrian and vehicular access is from Kimber Drive near the intersection of Baxter Street. Vehicles are permitted to make right and left turns into





Maple Elementary | *Site Analysis*

PLANTED AREA

IMAGE KEYS

3501 Kimber Driæ , Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017

Perimeter Circulation

Image E





4. PERMANENT CLASSROOM

5. PERMANENT CLASSROOM

9. PORTABLE CLASSROOM

X. LUNCH SHELTER



Maple Elementary School's 'pinwheel' layout of the original classroom buildings provides appropriately sized classrooms and valuable shared support spaces. The five primary classroom buildings along with the Kindergarten Classroom building and Administration/Multi-Purpose/Library building form multiple courtyards between the buildings. These courtyards serve as small gathering spaces to expand the education areas beyond the classroom walls and as quieter smaller scaled play areas. Portable building additions to the campus provide classroom-sized spaces for Child Care and Student Support services.

The current configurations of some doors on the campus and combination sink and drinking fountain stations within classrooms do not meet current accessibility standards.



ASPHALT

CONCRETE

Maple Elementary | Site Analysis

IMAGE KEYS

BUILDING NUMBERS

(#)

3501 Kimber Drie , Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017

Campus













Maple Elementary | Site Analysis

3501 Kimber Drie , Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017

Opportunities for Improvement

Maple's current parking lot layout does not adequately serve the parking needs for staff/visitors. Additional parking stalls and/or a re-design of

Image E



informal meetings.

Increasing the size of the library may provide greater usage potential for larger groups of students.







Maple Elementary | Site Analysis

3501 Kimber Drie , Newbury Park, CA 91320 Conejo Valley Unified School District April 5, 2017

Opportunities for Improvement

The addition of a conference room for use by the staff for meetings would permit groups to gather without relying on the availability of the MPR or Library. This may also provide a space for Professional Development. The campus also lacks a true staff lounge. Providing this space in addition to a meeting room would offer flexibility to the staff for both formal and

The stacked condensers along the exteriors of the buildings have a tendency to overheat and shut-down on days of extreme heat. A mechanical solution to separate the condensers from each other could eliminate this issue.

Repair and new paint to the exterior wooden exposed beams, fascia and window infill panels may provide a fresh face-lift to the campus. The Multipurpose-administration building shows particular need.

General campus storage is lacking. Provisions for storing additional furniture or seasonal items could alleviate the clutter caused by storing such items in other usable spaces.

Image B

Image C